

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 432Date: 11/06/2026

It is certified that an inspection team headed by Mr. D.P. Singh Lab -
Incharge / Sub Engineer PHED Gwalior. (Name of Officers
with designation) from Mrs. Anita Jayant Chemist PHED Gwalior (Name of
Department/Office) inspected the Kiddy's Corner Higher Secondary
School Shivpuri Link Road, Gwalior M.P. (Name & Address of
the School) on 10/06/2026 and found that the KIDDY'S CORNER HIGHER
SECONDARY SCHOOL SHIVPURI LINK ROAD Gwalior (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

Signature with Seal

Name

Designation

D.P.S.
Lab Incharge
Distrect Water Testing Laboratory
P.H.E. Division, Gwalior (M.P)

: D.P. Singh: Sub Engineer / Lab Incharge
PHED Gwalior.

To

Principal
Kiddy's Corner Higher Secondary
School Shivpuri Link Road
Gwalior. M.P.
(Name & Address of the Institution)

Public Health Engineering Department District Water- Testing Laboratory Gwalior

Test Report

Type of sample: Water Sample

Particular of sample : collected / not collected by PHED

Particular of sender:- Principal Kiddy's Corner Hr. Secondary School Shivpuri link Road Gwalior (M.P.)

Sample No.	Place of Collection and Details of Sample	Date of collection
1	Drinking Water	09.06.2026
2		
3		
4		

Particular of Sample :

Date of Receipt: 09.06.2026

Time of Receipt: 11:20 AM

Lab Reference No:

Date of Analysis: 09.06.2026

Nature of Study – Chemical and Bacteriological Analysis

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
PHYSICAL TEST								
1	Turbidity	NTU	1.0	5.0	1.5	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
CHEMICAL TEST								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.2	-	-	-
6	Alkalinity	Mg/L	200	600	86	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	30	-	-	-
8	Nitrate as No3	Mg/L	45	45	05	-	-	-
9	Total hardness	Mg/L	200	600	112	-	-	-
10	Calcium as Ca	Mg/L	75	200	27	-	-	-
11	Magnesium as mg	Mg/L	30	100	11	-	-	-
12	Iron	Mg/L	0.3	1.0	0.10	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-	-	-
14	T.D.S.	Mg/L	500	2000	234	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.12	-	-	-
16	Sulphate as SO4	Mg/L	200	400	05	-	-	-
BECT. FEACAL TEST								
17	Total Coliform	per 100 ml	Nil		-	-	-	-
18	E Coll or Thermo tolerant coliforms	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to TEST samples and parameters TEST.
- Samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Signature of Analyst

District Water Testing Lab
P.H.E. Division Gwalior

No. 432 /PHED/ Date :- 11/06/2026

Lab In Charge

P.H.E.D. Water Testing Laboratory
P.H.E. Division Gwalior (M.P.)